



NOTES:

1. For Manholes with internal drop connection increase manhole diameter to 1200.
2. For manholes with more than two internal drops increase diameter to minimum 1350 diameter.
3. May increase to 350mm with heavy duty lids where fixed surface levels are to be matched.
4. The manhole throat is to be made from insitu 17.5 MPa concrete. The use of pre-cast rings is prohibited.



Head Office: 50 Centreway Road, Orewa
 Private Bag 500, Orewa, 1461, New Zealand
 Tel: 0800 4265169, Fax (09) 4267280
 Email: info@rodney.govt.nz

26 February 2009

STANDARD DETAIL:

**WASTEWATER
 MANHOLE**

Copyright on this Drawing is Reserved
 DATE: June 2005
 NOT TO SCALE

RDC NO: SHEET NO: REV:

18000 5.4